



Public Health Laboratory

Surat Municipal Corporation
2nd Floor, Vesu Urban Community Health Center,
Opp. Vesu Fire Station, VIP Road,
Vesu, Surat - 395007 Gujarat

Name And Address of Applicant-	Gajera International School Katargam - Amroli Road Surat 395004			Report No.	No.Q-3/PHL/WC/I-55/2026-27
				Receipt No.	967507
				ULR No.	-
				Date of Sample	14/09/2026
Type of Sample:-	Private	Register Entry No.	55	Start Date of Analysis	19/09/2026
Source of the Water:-	Drinking Water			End Date of Analysis	19/09/2026

Test Report

Sample Description :- A Plastic Bottle

Physical Appearance: - Clear Liquid

Sr. No.	Quality Characteristic Test	Name of Method of test used	Unit	Result	Prescribed std. as per Regulations No. 2.10.9 & as per provision of the Act, Rules & Regulations
1.	Colour	FSSAI Manual of Method-2016 Water Section A Method No.I.1.	Hazen unit	1	Max.5
2.	Taste	FSSAI Manual of Method-2016 Water Section A Method No.I.4.	-	Agreeable	Agreeable
3.	Odour	FSSAI Manual of Method-2016 Water Section A Method No.I.2.	-	Agreeable	Agreeable
4.	pH Value	FSSAI Manual of Method-2016 Water Section A Method No.I.3.	-	6.9	6.5 To 8.5
5.	Ammonia (as Total Ammonia-N)	FSSAI Manual of Method-2016 Water Section A Method No.II.1.	mg/l	Absent	Max. 0.5
6.	Nitrate (as NO ₃)	FSSAI Manual of Method-2016 Water Section A Method No.II.4.	mg/l	Absent	Max. 45
7.	Chlorides (as Cl)	FSSAI Manual of Method-2016 Water Section A Method No.II.5.	mg/l	20.0	Max. 250
8.	Total Alkalinity (as HCO ₃)	FSSAI Manual of Method-2016 Water Section A Method No. II.9.	mg/l	50.0	Max. 200
9.	Total hardness (as CaCO ₃)	FSSAI Manual of Method-2016 Water Section A Method No.II.8.	mg/l	30.0	Max.200
10.	Total Dissolved Solids	FSSAI Manual of Method-2016 Water Section A Method No.I.6.	mg/l	100.0	Max. 500

Opinion: With respect to the test and observation performed, above sample of Drinking Water (R.O Water) conforms to the standards and provisions of Food Safety and Standards Act, 2006 and FSS Rules & Regulations.

.....end of the test report.....

DR. ANUPAMA BHATI
PRINCIPAL

Report Issued
Date: 21/09/2026
GAJERA INTERNATIONAL SCHOOL
AMROLI ROAD, KATARGAM, SURAT-4.

AFF NO: 430092 | SCHOOL CODE: 10082

SMT. SHANTABEN HARIBHAI GAJERA CHARITABLE TRUST

PRESIDENT

TRUSTEE

Food Analyst
Public Health Laboratory
Surat Municipal Corporation
Surat

Note:-
❖ Sampling is not carried out by our authority therefore, the result contained on this report relate only to the sample material tested.
❖ Sample drawn by party. Report is meant for guidance only. It is not valid for any litigation or Publicity purpose.

